

CERTIFICATE OF COMPLIANCE

Certificate Number 20141008-EX26510
Report Reference EX26510-20140804
Issue Date 2014-OCTOBER-08

Issued to: ERBOSAN ERCIYAS BORU SAN.VE TIC. A.S.
Anbar Mahallesi 895
Sokak PK.375 TURKEY

This is to certify that
representative samples of

METALLIC SPRINKLER PIPE

Schedule 10 and Schedule 40 steel sprinkler pipe for wet, dry, preaction and deluge type sprinkler systems with unthreaded ends intended to be joined by welding or Listed Rubber Gasketed Fittings when installed in accordance with the fitting manufacturer's specifications.

Schedule 10 sprinkler pipe - 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 6, and 8 in. nominal diameter (ASTM A795 and ASTM A53 Grade A, Type E)

Schedule 40 steel sprinkler pipe - 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 5, 6, and 8 in. nominal diameter (ASTM A53 Grade A and Grade B, Type E)

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: Standard for Metallic Sprinkler Pipe for Fire Protection Service, UL 852.

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

